



DEPARTMENT OF PUBLIC HEALTH & PREVENTIVE MEDICINE  
SANITARY CERTIFICATE

(Issued under Provision of Health act 1939 under section (ses 21,33,64,6798,106)

I here declare that I have inspected VEVEAHAM PRIME ACADEMY SCHOOL, S.F.NO:63 & 75/1 D2, UTHUPALAYAM, UDUMALPET ROAD, DHARAPURAM - TK, TIRUPPUR DT - 638 672. Inspecting the building and premises on the day of and certify 23.05.2023


- The Classroom and surroundings are maintained neat and clean.
- The Sanitary arrangements provided are adequate and satisfactory.
- The drinking water arrangements provided is satisfactory.

**This Certificate is issued subject to the following conditions:**

- The Garbage generated within the Classroom premises should be collected and disposed of properly by appointing required sanitary staff.
- On any account, the Garbage should not be burnt.
- The Children should be educated to prevent the usage of plastics in the Classroom Institution premises and no one should bring plastic carry bags, use and throw Tumblers to the Classroom/ Institution.
- N.O.C should be obtained from the Deputy Director of health services, to run a food establishment within in premises.
- Fire precaution measures and first Aid Box, should be provided.
- Child Labour should not be engaged in any account.
- Every person in charge of place should be display and exhibit a board stating that the place is a "No Smoking and No Spitting place" and that "Smoking or Spitting is an offence".
- This certificate issued is liable to be cancelled at any time on infringement if any of the above said conditions and for improper maintance of sanitation, improper maintance of the building as well as toilets in the Classroom/ Institute.
- This Sanitary Certificate valid for one year from the date issue.
- Any out break of communicable disease must be informed to the Health authorizes concerned immediately.
- All the food handlers should get the medical check up for every 6 months and the fitness certificate must be submitted.
- The store rooms must be rodent free. And verified for expiry of manufactures.
- This Sanitary Certificate valid one year only from the date of issue.

LD is No 4078/A4/2023 Dated : 23.05.2023

Countersigned


  
The Deputy Director of Health Services,  
Tiruppur.

To

VEVEAHAM PRIME ACADEMY SCHOOL,  
S.F.NO:63 & 75/1 D2, UTHUPALAYAM,  
UDUMALPET ROAD, DHARAPURAM - TK,  
TIRUPPUR DT - 638 672.



**PRINCIPAL**  
Veveaham Prime Academy,  
DHARAPURAM - 638 672  
TIRUPUR [D.T]

  
BLOCK HEALTH SUPERVISOR,  
GOVT. PRIMARY HEALTH CENTRE,  
PONNAPURAM.



For Ponnakal Charitable Trust,  
  
Chairman.

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE


No. 4078/2023

Dated: 22.05.2023

It is certified that an inspection team headed by Dr.A.A.THENMOZHI,BLOCK MEDICAL OFFICER, GOVT. PRIMARY HEALTH CENTRE,PONNAPURAM,TIRUPPUR DT from DEPT. OF HEALTH inspected the VEVEAHAM PRIME ACADEMY at S.F.No.63,75/1D2, UTHUPALAYAM VILLAGE, DHALAVAAIPATTINAM PANCHAYAT & POST,DHARAPURAM TALUK, TIRUPPUR DISTRICT, TAMILNADU on 22.05.2023 and found that the VEVEAHAM PRIME ACADEMY has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of ONE YEAR.

Signature with Seal:



Name : Dr.A.A.THENMOZHI  
Block Medical Office  
Govt. Primary Health Centre


Designation : BLOCK MEDICAL OFFICER  
Ponnapuram

Name & Address of the Office / Department : GOVT. PRIMARY HEALTH CENTRE,  
PONNAPURAM,  
TIRUPPUR DT,TAMILNADU.

Block Medical Office  
Govt. Primary Health Centre  
Ponnapuram

To  
THE CORRESPONDENT,  
VEVEAHAM PRIME ACADEMY,  
S.F.No.63,75/1D2,UTHUPALAYAM VILLAGE,  
DHALAVAAIPATTINAM PANCHAYAT & POST,  
DHARAPURAM TALUK,  
TIRUPPUR DISTRICT,  
TAMILNADU.

  
PRINCIPAL  
Veveaham Prime Academy,  
DHARAPURAM - 638 672  
TIRUPUR [D.T]

For Ponnakal Charitable Trust  
  
Chairman

**GEO ENVIRO SOLUTION**

AN ISO 9001:2015 CERTIFIED COMPANY

No:25/10, First Floor, New Colony 2<sup>nd</sup> Street, Mannarpuram, Trichy 620020.**TEST REPORT**

Off: 9843166130

Email : nelson.geoenviro@gmail.com

<b>Report No #</b>	<b>GES/23-24/040</b>	<b>Date</b>	<b>11/05/2023</b>	
<b>Client's Name &amp; Address</b> VEVEAHAM PRIME ACADEMY, S.F.NO.63,75/1D2 UTHUPALAYAM VILLAGE, DHALAVAIPATTINAM PANCHAYAT & POST, DHARAPURAM - 638672, TIRUPPUR DT.		<b>Sample Mark</b>	RO Water	
		<b>Sample Drawn By</b>	Customer (Ref - Mr Saravanan)	
		<b>Sample Description</b>	Water	
		<b>Page</b>	1 of 1	
<b>Branch Address</b> Geo Enviro Solution 101/5, Anna Salai, Vijayalakshampuram, Ambattur Chennai - 600 053		<b>Received On</b>	10/05/2023	
		<b>Commenced On</b>	11/05/2023	
		<b>Completed On</b>	11/05/2023	
		<b>Documents</b>	Trichy Office	
<b>Sl.#</b>	<b>PARAMETERS</b>	<b>UNITS</b>	<b>RESULTS</b>	<b>IS10500 R2017 2<sup>nd</sup> Rev Limits</b>
1	Turbidity	NTU	0.0	2.0
2	Electrical conductivity @ 25°C	micromhos/cm	46.7	-
3	pH Value @ 25°C	-	6.52	6.5 - 8.5
4	Total Dissolved Solids	mg/l	28	500
5	Total Hardness as CaCo3	mg/l	2	200
6	Calcium Hardness as CaCo3	mg/l	2	-
7	Magnesium Hardness CaCo3	mg/l	0	-
8	Calcium as Ca	mg/l	0.8	75
9	Magnesium as Mg	mg/l	Nil	30
10	Total Alkalinity as CaCo3	mg/l	12	200
11	P.Alkalinity as CaCo3	mg/l	Nil	-
12	M.Alkalinity as CaCo3	mg/l	12	-
13	Ammonia as NH <sub>3</sub>	mg/l	0.2	0.5
14	Chlorides as Cl	mg/l	7	250
15	Residual Chlorine	mg/l	Nil	0.0
16	Total Iron as Fe	mg/l	0.0	0.3
17	Fluorides as F	mg/l	0.18	1.0
18	Silica	mg/l	0	-
19	Nitrates as NO <sub>3</sub>	mg/l	4.1	45
20	Nitrite as NO <sub>2</sub>	mg/l	0.16	-
21	Phosphates as PO <sub>4</sub> <sup>3-</sup>	mg/l	0.24	-


Remarks : The Sample meets the requirement of IS 10500, R 2017 2<sup>nd</sup> Rev for Portability with respect to the Parameters Tested.

For Geo Enviro Solution

G. Jayachy  
Lab Chemist



  
**PRINCIPAL**  
Veveaham Prime Academy,  
DHARAPURAM - 638 672  
TIRUPUR [D.T]

For Ponmakal Charitable Trust  
  
Chairman